

REQUEST FOR INFORMATION (RFI)
VA-251-12-B-0113

PROJECT NUMBER:	655-11-102	Please ensure that before submitting questions or requests for clarification that you thoroughly read the solicitation, specifications, drawings and other pertinent documents. When submitting questions on this project the Government requires contractors to specifically identify the specification and/or solicitation section(s) or drawing number(s) in reference to the question or request for clarification submitted. No question or request for clarification will be answered by the Government unless the above requirements are met. Failure to comply may prevent the Government from responding in a timely manner.	
PROJECT TITLE:	Domestic Water & Restroom Renovations		
PROJECT LOCATION:	Department of Veterans Affairs Saginaw VA Medical Center 1500 Weiss Street Saginaw, MI 48602		
SUBMITTED BY:	N/A	City/State:	N/A
PHONE NO.:	N/A		

TO:

Sonny Earls, Contract Specialist
Department of Veterans Affairs
Aleda E. Lutz VA Medical Center
1500 Weiss St.
Saginaw, MI 48602

RFI NO.: One	DATE: August 22, 2012	SPEC/DWG. REFERENCE:
REPLY NEEDED BY: 8/27/2012		

INFORMATION NEEDED:

1. Is there a lead report we can use as reference since the drawings and specifications do not clearly show or describe the lead contaminated areas.
2. Dwg 1-ED110 – Keyed Notes. No lighting schedule found on drawings for the following items – specifications provide only general description of lighting fixtures but do not provide specific details or acceptable mfrs for the light fixtures below. Can a lighting schedule be provided for keyed notes below?
 - a. Number 10 – Reconnect new lighting to the (e) lighting circuit for the room.
 - b. Number 14 – Connect new corridor lights to the existing corridor lighting circuit and switching
 - c. Number 23 – Provide fluorescent dimmable can light with compatible slide dimmer and occupancy sensor
3. Dumpster – Will there be a designated area to place dumpster for waste removal?
4. Items to be re-used – Will there be a designated storage area for items to be removed or will the successful bidder have an opportunity to place a small storage container unit to store materials to be reused.

REPLY:

1. Refer to the posted lead reports on FBO, for building 1, 2, 3 and 4.
2. Refer to Sheet 1-E100 Symbol Legend. Lighting fixtures are called out in this location.
- 3&4. Yes, the VA will provide 2 parking spaces to the contractor for a dumpster and storage container to be located.

REPLY FROM: Kevin Russell, PE, VA Engineering, COR	DATE: 22 August 2012
ATTACHMENTS: Lead Reports for B1, B2, B3, and B4.	COPY TO: www.fbo.gov .